



CUADRO DE CARGAS											
DIAGRAMA DE CONEXIONES	CTO.		VOLTS.	WATTS A FASE			1 p. C APMPS.	COND. MINIMO.	TIERRA FISICA	PROTECTOR TERMOMAGNETICO 1 POLO 20 Amperes	
	No.	<div><div></div><div>2x18 W 45 W</div></div> <div><div></div><div>180 W</div></div>		A	B	C					
<div>NEUTRO</div> <div>A A</div> <div>(1) (R)</div> <div>(R) (R)</div>	1	5	1	127	405			3.54	12	12 t	1
TOTAL	5	1			405						
TAB. 1F - 2H, SQUARE D QO-4F TIPO INDUSTRIAL TOTAL WATTS = 405											

03 de 03